

**FORM HLW-6 MANUFACTURER'S DATA REPORT FOR  
WATER HEATERS OR STORAGE TANKS**  
As Required by the Provisions of the ASME Code Rules

1. Manufactured and certified by Hayward Industries, Inc., 2935 Sidco Drive, Nashville, Tennessee, 37204  
(name and address of manufacturer)

2. Manufactured for Stock  
(name and address of purchaser)

3. Location of Installation Stock  
(name and address)

4. Identification 21131712100161001 to 21131712100180001 (manufacturer's serial no.) N/A (CRN) 2902586801 Rev T (drawing no.) 6223-6242 (National Board no.) 2017 (year built)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to Part HLW, Section IV  
2015 (year) N/A [addenda (as applicable) (date)] 2768 (Code Case no.)

6. Shell 1 (no.) SB-584 (C90300) (material spec., gr.) .300 (thickness) None (lining) 2.88" ID (diameter) 0' 14.96" [length(overall)]

7. Joints Seamless "Casting" [long. (seamless, welded)] 80% [eff. (compared to seamless)] Seamless "Casting" [girth (seamless, welded)] 1 (no. of shell courses)

8. Heads Flat

Location	Material Spec., Gr., Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Flat Diameter	Side Pressure (concave, convex)
<b>END</b>	<b>SB-584 (C90300) .250"</b>	<b>N/A</b>			<b>4.75"</b>	

9. Tubesheet SA-240 T304 Tubes 4 (no.) .750 in (size) 5' 8.717" [length(overall)] SB-543 (C70600) (mat'l spec., gr.) .049 in (thickness) Both (rolled or welded)

10. Nozzles, inspection, and safety valve openings:

Purpose (inlet, outlet, drain, etc.)	No.	Diameter or Size	Type	How Attached	Material	Nominal Thickness	Reinforcement Material	Location
Handhole			N/A		N/A		N/A	
Inlet/Outlet Port	2	2.40	Flanged	Cast	SB584/C90300	.300		Shell
Drain Valve Port	1	3/4"NPT	Female Thrd	Machined		Thrd Opening		Shell
Pressure Relief Valve	1	3/4"NPT	Female Thrd	Machined		Thrd Opening		Shell
Temp Sensor Ports	2	1/4"NPT	Female Thrd	Machined		Thrd Opening		Shell
Pressure Sensor Port	1	1/8"NPT	Female Thrd	Machined		Thrd Opening		Shell
Thermistor Temp Sensor Port	1	3/8"NPT	Female Thrd	Machined		Thrd Opening		Shell

11. MAWP 125 psi Max. input 500,000 BTU Max. temp. 140 °F Hydrostatic test 188 psi

12. Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items for this report

N/A  
(name of part, item no., manufacturer's name, identification stamps)

13. Remarks

Cast header is also called the shell as referred to in section 6,7, and 10 above. 3/4" and below ports are drilled and tapped openings in shell casting.

Manufactured by Hayward Industries, Inc., 2935 Sidco Drive, Nashville, Tennessee, 37204

Mfr's Serial No. 21131712100161001 to 21131712100180001

National Board No. 6223-6242

**CERTIFICATE OF SHOP COMPLIANCE**

We certify that the statements made in this data report are correct and that all details of design, material, construction, and workmanship of this water heater or storage tank conform to Section IV of the ASME BOILER AND PRESSURE VESSEL CODE.

"HLW" Certificate of Authorization no. 40380 expiration date 2/16/2020

Date 12/9/2017 Name Hayward Industries, Inc.  
(manufacturer that constructed and certified water heater or storage tank)

Signed *Rory Hall*  
(by representative)

**CERTIFICATE OF SHOP INSPECTION**

Constructed by Hayward Industries, Inc. at 2935 Sidco Drive, Nashville, Tennessee, 37204

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and employed by The Hartford Steam Boiler Inspection and Insurance Company

have inspected parts referred to as data items 6 thru 11

and have examined Manufacturer's Partial Data Report for items

and state that, to the best of my knowledge and belief, the manufacturer has constructed the water heater or storage tank in accordance with Section IV of the ASME BOILER AND PRESSURE VESSEL CODE.

By signing this certificate, neither this Inspector, nor his employer makes any warranty, expressed or implied, concerning the water heater or storage tank described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 12/9/2017 Signed *William R. Foster*  
(Authorized Inspector)

Commission 15227  
(National Board commission number and endorsement)