

**FORM HLW-6 MANUFACTURER'S DATA REPORT FOR
WATER HEATERS OR STORAGE TANKS**
As Required by the Provisions of the ASME Code Rules

1. Manufactured and certified by Hayward Industries, Inc., 2935 Sidco Drive, Nashville, Tennessee, 37204
(name and address of manufacturer)

2. Manufactured for Stock
(name and address of purchaser)

3. Location of Installation Stock
(name and address)

4. Identification 21132005103258001 thru N/A 2902586801 Rev Y 9679-9718 2020
(manufacturer's serial no.) (CRN) (drawing no.) (National Board no.) (year built)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE.
The design, construction, and workmanship conform to Part HLW, Section IV 2019 N/A 2768
(year) [addenda (as applicable) (date)] (Code Case no.)

6. Shell 1 SB-584 (C90300) .300 None 2.88" ID 0.96"
(no.) (material spec., gr.) (thickness) (lining) (diameter) [length(overall)]

7. Joints Seamless "Casting" 80% Seamless "Casting" 1
[long. (seamless, welded)] [eff. (compared to seamless)] [girth (seamless, welded)] (no. of shell courses)

8. Heads Flat

| Location | Material Spec., Gr., Thickness | Crown Radius | Knuckle Radius | Elliptical Ratio | Flat Diameter | Side Pressure (concave, convex) |
|------------|--------------------------------|--------------|----------------|------------------|---------------|---------------------------------|
| END | SB-584 (C90300) .250" | N/A | | | 4.75" | |

9. Tubesheet SB-248 (C70600) Tubes 4 .750 in 5' 8.717" SB-543 (C70600) .049 in Both
(material spec., gr.) (no.) (size) [length(overall)] (mat'l spec., gr.) (thickness) (rolled or welded)

10. Nozzles, inspection, and safety valve openings:

| Purpose (inlet, outlet, drain, etc.) | No. | Diameter or Size | Type | How Attached | Material | Nominal Thickness | Reinforcement Material | Location |
|--------------------------------------|-----|------------------|-------------|--------------|--------------|-------------------|------------------------|----------|
| Handhole | | | N/A | | N/A | | N/A | |
| Inlet/Outlet Port | 2 | 2.40 | Flanged | Cast | SB584/C90300 | .300 | | Shell |
| Drain Valve Port | 1 | 3/4"NPT | Female Thrd | Machined | | Thrd Opening | | Shell |
| Pressure Relief Valve | 1 | 3/4"NPT | Female Thrd | Machined | | Thrd Opening | | Shell |
| Temp Sensor Ports | 2 | 1/4"NPT | Female Thrd | Machined | | Thrd Opening | | Shell |
| Pressure Sensor Port | 1 | 1/8"NPT | Female Thrd | Machined | | Thrd Opening | | Shell |
| Thermistor Temp Sensor Port | 1 | 3/8"NPT | Female Thrd | Machined | | Thrd Opening | | Shell |

11. MAWP 116 psi Max. input 500,000 BTU/HR Max. temp. 140 °F Hydrostatic test 174 psi

12. Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items for this report

N/A
(name of part, item no., manufacturer's name, identification stamps)

13. Remarks

Cast header is also called the shell as referred to in section 6,7, and 10 above.
3/4" and below ports are drilled and tapped openings in shell casting.

HLW-6

Manufactured by Hayward Industries, Inc., 2935 Sidco Drive, Nashville, Tennessee, 37204

Mfr's Serial No. 21132005103258001 thru 21132005103297001

National Board No. 9679-9718

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this data report are correct and that all details of design, material, construction, and workmanship of this water heater or storage tank conform to Section IV of the ASME BOILER AND PRESSURE VESSEL CODE.

"HLW" Certificate of Authorization no. 40380 expiration date 2/16/2023

Date 5/22/2020 Name Hayward Industries, Inc.
(manufacturer that constructed and certified water heater or storage tank)

Signed *Rory Hall*
(by representative)

CERTIFICATE OF SHOP INSPECTION

Constructed by Hayward Industries, Inc. at 2935 Sidco Drive, Nashville, Tennessee, 37204

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and employed by

The Hartford Steam Boiler Inspection and Insurance Company

have inspected parts referred to as data items 6 thru 11

and have examined Manufacturer's Partial Data Report for items

and state that, to the best of my knowledge and belief, the manufacturer has constructed the water heater or storage tank in accordance with Section IV of the ASME BOILER AND PRESSURE VESSEL CODE.

By signing this certificate, neither this Inspector, nor his employer makes any warranty, expressed or implied, concerning the water heater or storage tank described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 5/22/2020 Signed *William R. Koster*
(Authorized Inspector)

Commission 15227
(National Board Authorized Inspector Commission Number)